

ADDENDUM NO. 2

INVITATION TO BID #05-08

BID DESCRIPTION: Jetbridge Electrical Installation

ADDENDUM ISSUE DATE: March 2nd, 2005

BID OPENING DATE: March 7th, 2005

BID OPENING TIME: 9:45 AM

Please note the following changes to the Jetbridge Electrical Installation contract:

SECTION 16111-3.02

- a. Change section B to read:
“All exterior above grade conduit shall be galvanized rigid steel conduit (GRS) type, except where noted otherwise.”

- b. Change section D to read:
“Exposed interior conduit shall be EMT type, except where noted otherwise.”

Your signature verifies that your bid has been submitted based upon the above information clarification. Please submit the signed Acknowledgement Page with all bid documents.

Acknowledgement Page

All Vendors shall acknowledge receipt and acceptance of this Addendum No. 2, by signing in the acknowledgment space provided below and submitting this acknowledgment page wither their proposal.

Receipt acknowledgement and conditions agreed to this ____ day of _____, 2005.

Vendor _____

By _____